



AVK Series 24 Wet Barrel Hydrants AWWA C503 Certificate of Compliance

This letter is to certify that all Series 24 bronze, stainless steel, and ductile iron Wet Barrel Fire Hydrants manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by AWWA C503.

Each hydrant is tested, after assembly, to a static pressure of 400 psi and is rated to 200 psi.

In addition, all American AVK fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information please feel free to contact us.

AMERICAN AVK COMPANY

2155 Meridian Blvd – Minden, NV. 89423 - Phone 775-552-1400 - Fax 775-783-7502
WWW.AVKUS.COM