



AVK Series 24 Wet Barrel Hydrants

AWWA C503 and UL Certificate of Compliance

This letter is to certify that all Series 24 bronze, stainless steel, and ductile iron Wet Barrel Fire Hydrants manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by AWWA C503.

Each hydrant is tested, after assembly, to a static pressure of 400 psi and is rated to 200 psi.

In addition, all American AVK fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of American AVK,

A handwritten signature in black ink, appearing to read 'John Wilber'.

John Wilber

VP Engineering
American AVK Company

American AVK Company

2155 Meridian Blvd
Minden, NV 89423

Tel: (775) 552-1400
Fax: (775) 552-1031

sales@avkus.com
www.americanavk.com

Expect... The logo for American AVK Company, featuring the letters 'AVR' in a bold, blue, stylized font.