



## **AVK Series 25 and 45 Gate Valves**

### **AWWA C509 Certificate of Compliance**

This letter is to certify that all 3-inch through 16-inch Series 25 and Series 45, NRS, and OS&Y resilient wedge gate valves manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by AWWA for Resilient Seated Gate Valves; ANSI/AWWA C509.

The valves are rated by American AVK Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and tested for complete operation at 250 psi and 25 psi before shipment.

In addition, all American AVK gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of American AVK,

A handwritten signature in black ink that reads "John Wilber".

John Wilber

VP Engineering  
American AVK Company

---

#### **American AVK Company**

2155 Meridian Blvd  
Minden, NV 89423

Tel: (775) 552-1400  
Fax: (775) 552-1031

sales@avkus.com  
[www.americanavk.com](http://www.americanavk.com)

Expect... The logo for American Valve Research (AVR) features the letters 'AVR' in a bold, blue, sans-serif font. The 'A' and 'V' are connected at the top, and the 'R' is positioned to the right of the 'V'.