



## **AVK Series 41 Check Valves**

### **AWWA C508 Certificate of Compliance**

This letter is to certify that all 3-inch through 12-inch Series 41 resilient seated and bronze seated check valves manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by AWWA for Swing Check Valves; ANSI/AWWA C508.

The valves are rated by American AVK Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and seal tested for complete operation at 250 psi.

If you have any questions or need further information, please feel free to contact us.

On behalf of American AVK,

A handwritten signature in black ink, appearing to read 'John Wilber', is placed above the printed name.

John Wilber

VP Engineering  
American AVK Company

---

#### **American AVK Company**

2155 Meridian Blvd  
Minden, NV 89423

Tel: (775) 552-1400  
Fax: (775) 552-1031

sales@avkus.com  
[www.americanavk.com](http://www.americanavk.com)

Expect... The AVK logo is placed to the right of the text 'Expect...'.